

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1098

OWNER	NAME Angioli Corp.		ADDRESS Ludingtonville Rd. Holmes, NY	
LOCATION OF WELL	(No. & Street) Fair St.		(Town) Patterson	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 41	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR		HOURS 2	G.P.M. 15 YIELD (G.P.M.) 15
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 35		DURING YIELD TEST (feet) total drawdown Depth of Completed Well in feet below Land surface: 325	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED	Diameter of well including gravel pack (inches) GRAVEL SIZE (inches) FROM (feet) TO (feet)
DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION		Sketch exact location of well with distances, to at least two permanent landmarks.
0 30		clay		
30 325		granite with quartz		
If yield was tested at different depths during drilling, list below				
FEET		GALLONS PER MINUTE		
DATE WELL COMPLETED 10/9/84		DATE OF REPORT 4/16/85		WELL DRILLER (Signature) 